



Middle Fork Irrigation District







Hydroelectric power is generated at three locations year around as an integral part of the Middle Fork Irrigation District water distribution system. Within each powerhouse are water turbine generators, control panels and the required hydraulic control and station service equipment. The three powerhouses, allowing for differences in turbine configuration and site requirements, are similar in design and construction. Pelton water turbines are used in powerhouses one and three, where water is returned to the stream at atmospheric pressure. The Francis turbine in powerhouse two is a totally enclosed pipeline system, where the operating head is determined by downstream conditions. Financing for the hydroelectric project totaled 7.5 million dollars.











Clear Branch Dam



The dam is an earth and rock zone fill approximately 1350 feet long with a top width of 28 feet. Height of the dam is 106 feet and water depth at the spillway crest elevation is 100 feet. Construction was under the authority of the Watershed Protection and Flood Prevention Act (Public Law 566).

Laurance Lake Reservoir



When full the spillway elevation is 2978 feet msl. The surface of Laurance lake is approximately 130 acres.

Minimum flow regimes below Clear Branch Dam are: 3 cfs for the period starting July 10 and extending through October 7 of each year. 50% of calculated reservoir inflow up to 20 cfs from October 8 through July 10.

These flows can be reduced at the discretion of the fishery management agencies if t would be in the interest of fisheries resources to do so in so far as such reduction does not interfere with the primary function of the reservoir.