

UNITED STATES OF AMERICA
FEDERAL ENERGY REGULATORY COMMISSION

Otis Hydroelectric Company)
) Project No. 8277-008
) Maine

ERRATA NOTICE

(October 16, 1998)

ORDER ISSUING NEW LICENSE

(September 16, 1998)

On September 16, 1998, an Order Issuing New License was issued for the Otis Hydroelectric Project. The following revision should be made.

(a) On page 1, paragraph 1, "October 25, 1997" should be replace with "September 25, 1997".

(b) On page 20, in license Article 409, "September 24, 1997" should be replaced with "September 25, 1997".

(c) On page 18, in license Article 403, "The purpose of the monitoring plan is to ensure that stream flows below the project, as measured immediately downstream of the project tailrace, maintains the minimum state standard for D.O. (D.O. concentrations at or above an instantaneous level of 5.0 mg/l or 60% saturation, whichever is higher, and a 30-day average concentration of 6.5 mg/l)." should be replaced with "The purpose of the monitoring plan is to ensure that the minimum state standard for D.O. (D.O. concentrations at or above an instantaneous level of 5.0 mg/l or 60% saturation, whichever is higher, and a 30-day average concentration of 6.5 mg/l), is maintained in the project area."

..... David P. Boergers
Secretary

981020-0307-3

FERC - DOCKETED

OCT 16 1998

lm